


# ADDENDUM

To:	<b>ALL TENDER DOCUMENT HOLDERS</b>	Addendum No:	<b>THREE</b>
Project:		No. of Pages	<b>2</b>
	<b>Dryden Youth Soccer Facility Rotary Park, Wice Road, Dryden, ON</b>	Date:	<b>May 15, 2017</b>
		KAL File No:	<b>14061</b>

Please note the following and attached clarification(s) and/or modification(s) to the Tender Documents for the above noted project and be governed accordingly. This addendum shall form part of the Contract Documents. **The Contractor shall acknowledge receipt of this Addendum on the Bid Form.**

ITEM NO.	REF. SPECIFICATION SECTION OR DWGS	DESCRIPTION
3.1	A-601	<u>Reference Room Finish Schedule on architectural drawing A-610:</u> Revise lobby (rm. 01) ceiling finish from <del>WD,VAR</del> to <b>GWB, PT.</b>
3.2	Electrical Drawings & Specifications	<u>Reference Mechanical Drawings and Specifications:</u> Reference the attached one (1) page Mechanical Addendum issued by MCW/AGE, dated May 12, 2017. Incorporate the entire contents of this addendum into the Tender Documents.

Issued By:

<b>KEEWATIN-ASKI LTD. Consulting Engineers &amp; Architect</b> Joanna Klein, OAA	<b>Telephone</b> (807) 737-3858	<b>Mobile</b> (807) 737-9129
<b>Signature</b> 	<b>Fax</b> (807) 737-3875	<b>Email</b> jklein@k-a.ca

Attachments

1	MCW/AGE Addendum dated May 12, 2017 (1 page)

**END OF ADDENDUM**



# Addendum

Date: May 12, 2017

210-1821 Wellington Avenue  
Winnipeg, Manitoba  
R3H 0G4

Phone (204) 779-7900  
Fax (204) 779-1119  
www.mcw.com

*Project Name:* Dryden Youth Soccer  
*Client:* Keewatin-Aski Ltd.  
*To:* Keewatin-Aski Ltd.  
*Attention:* Joanna Klein  
*Email Address:* jklein@k-a.ca  
*Distribution:*

*Project No.:* 11146  
*ADD No.:* 01M  
*Page No.:* 1 of 1  
*Office:* Thunder Bay  
*From:* Jody Swartman

---

In accordance with the drawings and specifications, provide in the tender all costs required to complete the work including items as listed below:

Re: Grease Interceptor

1. Replace the specified grease interceptor (G-1) with:

Watts Drainage Products WD-125 epoxy coated inside and outside fabricated steel grease interceptor with flow rating of 25 gpm and grease capacity of 50 lbs. Unit shall include one piece removable baffle assembly, code approved deep seal trap, secured and gasketed non slip cover, NH (MJ) (standard) inlet and outlet and external flow control.